

## ADDENDUM NO. 1

WATER MAIN PROJECT 700071  
SPEC. NO. 03-299IN YANKEE HILL ROAD FROM WILDERNESS ROAD TO 27<sup>TH</sup> STREET

## TO ALL PROSPECTIVE BIDDERS:

1. A 12-inch high pressure (HP) gas main is located under the existing pavement in Yankee Hill Road that is not shown on the plans. The gas main is not expected to pose a conflict to construction. However, the HP gas main is located approximately 22 feet south of the north section line of Sec 25, T9N, R6E (the former centerline of Yankee Hill Road). The proposed water line alignment is 56 feet south of this section line at the west end of the project and 43 feet south of this section line at the east end of the project. Therefore, the horizontal separation of the proposed water main alignment with the existing HP gas main varies from 34 feet at the west end to 21 feet at the east end. The plans will not be reissued for bidding purposes. The construction plans will be revised and reissued to reflect the location of this main before construction begins.

NOTE: Bidders are instructed to sign and fax this page of Addendum No. 1 back to the City of Lincoln Engineering Services, attention Mary Lowe at fax number 402-441-6576, as evidence that this Addendum No. 1 has been received. Failure to do so could result in rejection of your bid.

\_\_\_\_\_  
Company/Contact Person

